



**NOTES:**

WHERE IT IS ESSENTIAL TO PROVIDE UNINTERRUPTED WATER SERVICE, INSTALLATION OF TWO FRP DEVICES IN A BATTERY (PARALLEL) SETTING IS RECOMMENDED.

IF OPTIONAL AIR GAP DRAIN FUNNEL IS NOT INSTALLED, AN AIR GAP MUST BE PROVIDED BETWEEN THE OUTLET OF THE RELIEF VALVE AND ANY PIPING TO A DRAIN.

IF ANY QUESTIONS CONTACT C.C. CONTROL METER REPRESENTATIVE OR WATER DISTRIBUTION MANAGER AT LANCASTER DIVISION OF WATER.

APPROVED _____  _____ CITY ENGINEER	<p style="text-align: center;"><b>COLD WEATHER INDOOR/ABOVE GROUND INSTALLATION OF HIGH HAZARD BACKFLOW PREVENTER AND METER SET</b></p>	CITY OF LANCASTER, OHIO DEPARTMENT OF ENGINEERING				
REVISED: 8/15/13		<p style="text-align: center;">STANDARD CONSTRUCTION DRAWING</p> <table border="1" style="width: 100%;"> <tr> <td data-bbox="1071 1890 1299 1942">DWG. BY: ...MAC.....</td> <td data-bbox="1299 1890 1546 1942">FILE NUMBER</td> </tr> <tr> <td data-bbox="1071 1942 1299 1984">CHK'D BY: .....</td> <td data-bbox="1299 1942 1546 1984" style="text-align: center; font-size: 1.5em;"><b>W-19</b></td> </tr> </table>		DWG. BY: ...MAC.....	FILE NUMBER	CHK'D BY: .....
DWG. BY: ...MAC.....	FILE NUMBER					
CHK'D BY: .....	<b>W-19</b>					