



Pipe Diameter	
D1	D2
8"	8"
10"	8"
12"	10"
15"	10"
18"	12"
21"	12"
24"	12"

**NOTES:**

1. HEIGHT OF DROP PIPE IS TO BE AS SHOWN ON THE PLANS OR WILL BE DETERMINED AT THE TIME OF CONSTRUCTION.
2. ALL WORK AND MATERIALS REQUIRED TO CONSTRUCT THE INSIDE DROP SHOULD BE INCLUDED FOR PAYMENT UNDER ITEM 604, MANHOLES, OR ITEM 901, PIPE SEWERS COMPLETED IN PLACE.
3. MATERIAL FOR THE DROP PIPE AND BEND SHALL BE OF ONE TYPE AND BE ONE OF THE FOLLOWING: CAST IRON, ABS SOLID WALL OR PVC.

APPROVED <u>12-19-13</u>  CITY ENGINEER	<b>INSIDE DROP FOR MANHOLE</b>	CITY OF LANCASTER, OHIO DEPARTMENT OF ENGINEERING
REVISED: 12 DEC 13		<b>STANDARD CONSTRUCTION DRAWING</b>
		DWG. BY: <u>DDK</u> CHK'D BY: <u>RM</u>
		<b>FILE NUMBER S-17</b>