



NOTES:
 IF ANY QUESTIONS CONTACT C.C. CONTROL METER REPRESENTATIVE OR WATER DISTRIBUTION MANAGER AT LANCASTER DIVISION OF WATER.
 DIRECTIONAL VALVE HANDLES SHALL BE REMOVED OR CHAINED AND LOCKED.

APPROVED _____ _____ CITY ENGINEER	STANDARD MEDIUM HAZARD "Y" STRAINER/METER/BACKFLOW PREVENTER SET WITH FIRE LINE	CITY OF LANCASTER, OHIO DEPARTMENT OF ENGINEERING	
REVISED: 8/15/13		DWG. BY: ...MAC... CHK'D BY:	STANDARD CONSTRUCTION DRAWING FILE NUMBER W-21