



NOTES:

CURB STOP AND METER SET TO BE INSTALLED WITHIN A MINIMAL DISTANCE TO PROPERTY LINE AS APPROVED BY LANCASTER DIVISION OF WATER.

METER TO BE SET AT RIGHT ANGLES TO RIGHT-OF -WAY AND MUST BE LEVEL AND CENTERED WITH YOLK VALVES UPRIGHT.

METER ENCLOSURE DIAMETER SHALL BE 18" FOR 5/8", 3/4", AND 1" METERS.

METER ENCLOSURE COVER TO BE FORD METER BOX CO. NUMBER W-3 OR AN APPROVED EQUAL WITH AN 11 1/2" OPENING.

APPROVED _____ _____ CITY ENGINEER	STANDARD OUTSIDE METER SET FOR 5/8", 3/4", AND 1" METERS/BACKFLOW PREVENTERS	CITY OF LANCASTER, OHIO DEPARTMENT OF ENGINEERING	
REVISED: 8/15/13		STANDARD CONSTRUCTION DRAWING DWG. BY: ...MAC..... CHK'D BY: .....	FILE NUMBER <b>W-23</b>