

PROPOSED
PAVEMENT

EXISTING
GROUND LINE

EXISTING
GROUND LINE

R/W

12" MIN.

3'-6" MINIMUM

RELOCATE EXISTING
SERVICE BOX

CURB STOP

WATER LINE SHALL BE
LAID WITH MINIMUM OF
42" COVER

VARIES

CUT EXISTING WATER SERVICE
PIPE AND RECONNECT WITH
ADAPTER AS REQUIRED

APPROVED _____

CITY ENGINEER

WATER SERVICE
EXTENSION AND CURB
BOX RELOCATION

CITY OF LANCASTER, OHIO
DEPARTMENT OF ENGINEERING

STANDARD
CONSTRUCTION DRAWING

DWG. BY: ...MAC...
CHK'D BY:

FILE NUMBER
W-3

REVISED: 3/5/07