



**NOTES:**

DRAIN ROCK AROUND AND ABOVE HYDRANT DRAIN SHALL BE NO. 57 WASHED STONE OR GRAVEL. PLACE MIRAFI 140N OR EQUAL BETWEEN DRAIN ROCK AND FILL.

FIRE HYDRANTS TO BE SET 2'-6" BACK OF CURB AND 6' FROM EDGE OF ROAD.

STEAMER NOZZLE SHALL FACE THE STREET UNLESS OTHERWISE SPECIFIED.

APPROVED \_\_\_\_\_  
 \_\_\_\_\_  
 CITY ENGINEER

**TYPICAL HYDRANT  
 SETTING TYPE "A"**

CITY OF LANCASTER, OHIO  
 DEPARTMENT OF ENGINEERING

STANDARD  
 CONSTRUCTION DRAWING

DWG. BY: ...MAC...  
 CHK'D BY: .....

FILE NUMBER  
**W-7**

REVISED: 8/15/13