



PIPE DIAMETER	NO. OF RODS
4" & 6"	2
8"	3
10" & UP	4

NOTES:

TIME AND DURATION OF SHUTDOWN SHALL BE DETERMINED BY THE LANCASTER DIVISION OF WATER DISTRIBUTION MANAGER.

THE CONTRACTOR SHALL NOTIFY ALL WATER CUSTOMERS AFFECTED BY THE PROPOSED WORK AT LEAST 24 HOURS IN ADVANCE OF SHUTDOWN.

ALL BENDS SHALL BE SECURED BY WEDGE ACTION RETAINER RINGS, RODDING OR OTHER METHODS AS APPROVED BY THE INSPECTOR TO RESTORE THE MAIN TO SERVICE AS SOON AS POSSIBLE.

THE RELOCATED LINES SHALL BE LAID TO THE NEW LINE AND GRADE, TESTED, AND DISINFECTED PRIOR TO SHUTDOWN OF EXISTING MAIN AND CONNECTION OF THE RELOCATED LINES TO THE EXISTING MAIN.

ALL WATER LINES SHALL BE DISINFECTED BY SWABBING WITH A 5 PERCENT HYPOCHLORITE SOLUTION IN ACCORDANCE WITH APPLICABLE SECTIONS OF A.W.W.A. C-601.

APPROVED _____ _____ CITY ENGINEER	TYPICAL WATER LINE LOWERING	CITY OF LANCASTER, OHIO DEPARTMENT OF ENGINEERING						
REVISED: 8/15/13		<table border="1" style="width: 100%;"> <tr> <td colspan="2" style="text-align: center;">STANDARD CONSTRUCTION DRAWING</td> </tr> <tr> <td>DWG. BY: ...MAC.....</td> <td>FILE NUMBER</td> </tr> <tr> <td>CHK'D BY:</td> <td style="text-align: center; font-size: 1.5em;">W-11</td> </tr> </table>	STANDARD CONSTRUCTION DRAWING		DWG. BY: ...MAC.....	FILE NUMBER	CHK'D BY:	W-11
STANDARD CONSTRUCTION DRAWING								
DWG. BY: ...MAC.....	FILE NUMBER							
CHK'D BY:	W-11							