

TEMPORARY RESOLUTION NO. 122-20

PERMANENT RESOLUTION NO. 120-20

A RESOLUTION TO APPROPRIATE FROM THE UNENCUMBERED BALANCE AND TO AMEND THE CERTIFICATE OF APPROPRIATIONS WITH THE COUNTY AUDITOR IN THE PARKS IMPROVEMENTS FUND (3015)

WHEREAS, the Parks Department has contracted with Johnson Controls to upgrade the fire and security systems in the Olivedale Park Activities Center in the amount of Twenty-Two Thousand Six Hundred Ninety-Nine Dollars and Fifty-Six Cents (\$22,699.56); and

WHEREAS, the project is nearing completion and it has been discovered that 13 duct detectors in the existing fire alarm system, that were intended to be reused, are not compatible with the new system; and

WHEREAS, the additional project cost for 13 new duct detectors and related items is Twelve Thousand Nine Hundred Ninety-Eight Dollars and Six Cents (\$12,998.06) as set forth in Exhibit A attached hereto and incorporated herein;

BE IT RESOLVED BY COUNCIL OF THE CITY OF LANCASTER, OHIO

SECTION 1. That the City of Lancaster Auditor amend the Certificate of Appropriations with the County Auditor for the Parks Improvements Fund (3015) in the amount of Twelve Thousand Nine Hundred Ninety-Eight Dollars and Six Cents (\$12,998.06).

SECTION 2. That the City of Lancaster Auditor appropriate from the unencumbered balance in the Parks Improvements Fund (3015) in the expense account 3015.5020.56009 (Olivedale Recreation Center) in the amount of Twelve Thousand Nine Hundred Ninety-Eight Dollars and Six Cents (\$12,998.06) to pay for the unanticipated project costs.

SECTION 3. That this resolution shall take effect and be in force from and after the earliest period allowed by law.

Passed: 11/09/2020 after 1st reading. Vote: Yeas 8 Nays 0

Date Approved: 11/09/2020

Clerk: Deborah J. Julian

David C. Miller
President of Council

David L. Scheffer
Mayor

Offered by: May R. Turner

Second by: [Signature]

Requested by Service Committee

Tharp, Mike

From: Steven Cook <steven.cook@jci.com>
Sent: Thursday, October 29, 2020 10:59 AM
To: Tharp, Mike
Subject: Fire Alarm - Olivedale

[CAUTION: This message originated from an outside source -- DO NOT CLICK on links or open attachments unless you are sure the content is safe. If you have any questions, please contact IT.]

Hi Mike,

Following our conversation, please find confirmation of the additional work required for the Fire Alarm upgrade which was not accounted for in the original scope:

Replace & wire (13) Duct Smoke Detectors
Install & wire (13) Duct Smoke Test Stations
Install (13) Duct Smoke Sampling Tubes
Replace (3) Power Supply Units
Install (6) 12v Batteries
Locate and remove SIM Modules
Install and wire relay module for connection to elevator recall

Total additional cost having halved the equipment costs and reduced the labor charges is \$12,998.06

I appreciate that this is far from ideal, we never like having to be in this position. However, unfortunately these issues were things which could not have been foreseen.

Please let me know if you have any questions.

Thanks,

Steven Cook

Commercial Fire & Security Account Executive
VIDEO SURVEILLANCE | FIRE | INTRUSION | ACCESS CONTROL | SHOOTER DETECTION
Johnson Controls Security Solutions

+1 614 753 0985 Cell

steven.cook@jci.com
www.johnsoncontrols.com

Johnson Controls
6200 Shamrock Court
Dublin, OH 43016
USA

THIS MESSAGE MAY CONTAIN INFORMATION THAT IS PRIVILEGED AND CONFIDENTIAL. The information contained in, or attached to, this message is intended solely for the use of the specific person(s) named above. If you are not the intended recipient then you have received this communication in error and are prohibited from review, retransmission, taking any action in reliance upon, sharing the content of, disseminating or copying this message and any of the attachments in any way. If you have received this communication in error, please contact the sender immediately and promptly delete this message from all types of media and devices. Thank you.

