

# FOSTER CARE AND ADOPTION INSPECTIONS

---

The following is a guideline of suggested items that can be checked or addressed by you prior to your inspection. This list is intended to assist you in being better prepared at the time of your inspection, but may not account for every possible violation. Each inspection may incur its own unique circumstances isolated to that individual inspection. We hope this will allow your inspection process to progress smoothly.

- MUST PAY FOR INSPECTION PRIOR TO SCHEDULING
- ADDRESS NUMBERS MUST BE POSTED AND VISIBLE FROM STREET
- ALL SMOKE DETECTORS SHOULD BE TESTED PRIOR TO INSPECTION.
- THERE SHOULD BE ONE SMOKE DETECTOR ON EACH FLOOR & WE ENCOURAGE ONE DETECTOR IN EACH BEDROOM
- EXTENSION CORDS CAN **NOT** BE USED AS PERMANENT WIRING
- MUST HAVE A 5 LB. ABC EXTINGUISHER THAT HAS BEEN INSPECTED BY A LICENSED COMPANY WITH IN THE LAST YEAR.
- EXTINGUISHER MUST BE PERMENANTLY MOUNTED
- ANY BASEMENT SLEEPING QUARTERS TO BE USED BY THE CHILD MUST HAVE A SECOND EXIT.
- AN EMERGENCY ESCAPE ROUTE AND FIRE DRILL SCHEDULE SHOULD BE POSTED.