

Check Your Appliance Connections

Interior Piping and Gas Appliance Connector Safety

Some gas flexible appliance connectors manufactured from 1970 to 1980 can fail over time and should be replaced. All connectors should be regularly inspected for damage and replaced when a potential issue is found. Please know:

- Only a qualified individual should inspect or replace the gas connector because some connectors are brittle and could fail with very little movement.
- When disconnecting gas appliances, gas connectors should be removed and the fuel line must be plugged and capped to prevent unintentional operation.
- Gas pipes should be properly maintained and never used for purposes like hanging clothes or supporting other structures.

